


## Radiant systems

Radiation from different surfaces




Let us consider a panel with surface temperature  $t_p$  and a room at 20°C

$$q / A = \sigma_n \varepsilon (T_p^4 - T_s^4)$$

$t_p$ [°C]	$T_p$ [K]	$q/A$ [W/m <sup>2</sup> ]
28	300	43
50	322	180
100	372	613
200	472	2'181
400	672	10'101

## Water based suspended radiant systems




**Water at 90°C or pressurized water or vapour at 110-130°C.  
Length from 4 m to 6 m.  
Modular solution**





## Radiant Luminous Systems

The combustion chamber is in the ambient (need of adequate ventilation or open spaces)



## 5. DIRECT EXPANSION UNITS



## WATER AND AIR-WATER BASED SYSTEMS

### Heating operation

In the past the heating systems have been designed and they were supposed to operate at high temperature, due to the use of combustion boilers.

Hence the usual temperature in the '70ies was 90°C or even vapour or high pressure hot water.

In the '90ies the condensing boilers were introduced reducing the water temperature at 60°C or even less.

The increase use of radiant systems and of the heat pumps has also lead to further reduction of the water temperature in the building

### Usual temperatures in heating systems





Table 1. Definition of temperature ranges for heating designs

## Effectiveness coefficient in heating


It is a qualitative parameter which is not useful for sizing the systems, but it is interesting to show the qualitative efficiency for heating solutions:

$$\Phi = \frac{t_{\text{supply}} - t_{\text{return}}}{t_{\text{supply}} - t_i}$$




		Supply Temp.	Return Temp.	Effectiveness coefficient
A	High temperature radiators (70ies)	80	70	17%
B	Mid temperature radiators (90ies)	75	65	18%
C	Low temperature radiators (today)	55	49	17%
D	Fan-coil	45	40	20%
E	Chilled beams	35	30	33%
F	Radiant systems (90ies)	35	29	40%
G	Radiant systems (2000)	30	25	50%
H	Radiant systems (today)	26	22	67%

## Temperatures in cooling



## Effectiveness coefficient in cooling

		Supply Temp.	Return Temp.	Effectiveness coefficient
A	Fan coils	7	12	26%
B	All air/dehumidification	7	12	26%
C	Fan beams	15	18	27%
D	Radiant ceiling	17	20	33%
E	Radiant floor	19	21	29%
F	TABS	19	22	43%



## Hydronic terminal units

- *Radiators*
- *Finned coils/baseboard*
- *Convactor heating system*
- *Fan-coils*
- *Active beams / chilled beams*
- *Unit heaters*
- *Radiant systems*